



NOTES:

1. 300mm OR MOUNTING HEIGHT TO MATCH EXISTING OUTLET MOUNTING HEIGHT IN THE SAME ROOM.
2. MINIMUM CABLE BENDING RADIUS SHALL BE 1" OR 25mm.

				Building/Facility Name	
No.	BY	DATE	REVISIONS	App'd	
Scale		NONE		BY	DATE
Sheet No.		1 of 1		Drawn	MET 05 MAR 04
UBC Project No.				Check'd	TZ 5 FEB 14
				Design'd	
				Approv'd	B. MACDONALD-RCDD 15 FEB 14
This drawing and its contents are confidential, and are for the private information of the Client Name. It is not to be relied upon or used in whole or in part for other purposes or by or for the benefit of others without prior adaptation and specific written verification by UBC, Information Technology.				UNIVERSITY OF BRITISH COLUMBIA	
				File No.	ITSTD-49